

ATTESTATION OF CONFORMITY

Issued to: Hager Electro SAS
132 Boulevard d'Europe
67210 Obernai Cedex
France

For the product: Moulded Case Circuit-Breakers (MCCB)

Trade name: HAGER

Type/Model: h3 h1000,
HNE... *
(* = country version designation A;B;C...;Y;Z)

Ratings: In from 630 A to 1000 A, Ue 415 Vac, Icu 50 kA, Ics 50 kA, number of poles 3 P, 4 P

Manufactured by: Hager Electro SAS
132 Boulevard d'Europe
67210 Obernai Cedex
France

Subject: Type tests, according to sequence I, sequence II / III, sequence III and annex J.

Requirements: IEC60947-2(4th edition):2006 and A1:2009, clauses 8.3.3, 8.3.4, 8.3.5 and Annex J.


Remark: The above mentioned tests are performed with positive result.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 2135745.00.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 7 January 2011

Number: 2136823.01A



DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.