



## CB TEST CERTIFICATE

Ref. Certificate No.

BE-1827/A1

### IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	SGS Belgium NV - Division SGS CEBEC		
Product:	Residual current operated circuit-breakers (RCCB)		
Applicant:	Hager Electro S.A.S.	132, Boulevard d'Europe	France
		PO Box 3	
		67215 OBERNAI	
Manufacturer:	Hager Electro S.A.S.	132, Boulevard d'Europe	France
		PO Box 3	
		67215 OBERNAI	
Factory:	Hager Electro S.A.S.	132, Boulevard d'Europe	France
		PO Box 3	
		67215 OBERNAI	
Rating and principal characteristics:	See page 2		
Trade mark (if any):	HAGER		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	Cx xxx x / Cxx xxx x and Cxxx xxx x		
Additional information:	Editorial change of rated residual current		
Sample of product tested to be in conformity with IEC:	61008-1(ed.2);am1;am2		
Test Report Ref. No:	58198805/00 up to 58198805/09		

This CB Test Certificate is issued by the National Certification Body:

SGS Belgium NV - Division SGS CEBEC  
Business Riverside Park, Avenue Internationale laan 55 Build. D B - 1070  
Brussels, Belgium

Signed by: Calogero LANA

Date of issue: 2009-03-13

SGS



**Ratings:**

number of poles	:	1P+N & 3P+N, left and right neutral
rated voltage (Un)	:	240 V / 415 V
nature of supply	:	AC
rated frequency	:	50 Hz
rated current (In)	:	25 A up to 63 A
rated residual current (Idn)	:	0,1 A and 0,3 A
rated short-circuit current (Icn)	:	6000 A
residual current type	:	AC+S and A+S
rated cond. residual short-circuit current (Idc)	:	4500 A
rated making and breaking capacity (Im)	:	630 A / 1500 A
rated residual making and breaking capacity (Idm)	:	630 A / 1500 A
safety distance 'a'	:	35 mm
method of mounting	:	Panel Board Type
method of connection mounting	:	Not associated with the mechanical
terminals	:	Pillar terminal
rated ambient temperature (ta)	:	-25°C to +40°C
protection against electric shock	:	IP 20
other characteristics	:	Quick Bus Bar Terminal

---