

# KEMA Test Certificate

No. 2119511.03KTC

Issued to: Hager Electro SAS  
132, Boulevard d'Europe  
BP3 - 67215 Obernai  
France

For the product: Moulded case circuit-breakers

Trade name: HAGER

Type/Model: h3 x250  
HNB...\*  
(\* = country version designation A;B;C...;Y;Z)

Ratings: 3P, 3P+N, 4P; Ue = 415 Vac;  
In = from 100 to 250 A;  
Icu = 40 kA; Ics = 20 kA;

Subject: Type tests


Requirements: IEC 60947-2 (Fourth edition)  
IEC 60947-1 (Fifth edition)

Remarks: -

This Test Certificate is granted on account of an examination by KEMA, the results of which are laid down in test reports no. 2119511.50 to 2119511.55, dated November 6, 2009.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Test Certificate does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA.

KEMA Quality B.V.  
Arnhem, November 6, 2009



H.L. Schendstok  
Certification Manager

©Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

KEMA Quality B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands  
T +31 26 3 56 20 00 F +31 26 3 52 58 00 [contact@kema.com](mailto:contact@kema.com) [www.kema.com](http://www.kema.com) Registered Arnhem 09085396

Experience you can trust.