

ATTESTATION OF CONFORMITY

No. 2109150.01/A

Issued to: Hager Electro SAS
132 Boulevard d'Europe
67210 OBERNAI CEDEX
FRANCE

For the product: Air Circuit Breakers

Trade name: HAGER

Types/Models: hw1600n, hw2500s, hw2500n, hw4000p, hw4000n

Ratings: Ue 415 Vac, 50/60 Hz, Ui 1000 V, Uimp 12 kV, 3- or 4-pole
hw1600n, Ith 400-1600 A, Icm 143 kA,
Icu = Ics = Icw 65 kA
hw2500s, hw2500n, Ith 2000-2500 A,
Icm 176 kA, Icu = Ics = Icw 80 kA
hw4000p, hw4000n, Ith 3200-4000 A,
Icm 220 kA, Icu = Ics = Icw 100 kA
fixed or withdrawable

Subject: Type test

Requirements: IEC 60947-2(ed.3)

This Attestation is granted on account of an examination by KEMA, the results of which are laid down in a confidential file no. 2109150.00

The examination has been carried out on one single specimen of the product, submitted by the manufacturers. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA

KEMA Quality B.V.
Arnhem, August 14, 2007



H.L. Schendstok
Certification Manager

©Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

KEMA Quality B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands
T +31 26 3 56 20 00 F +31 26 3 52 58 00 customer@kema.com www.kema.com Registered Arnhem 09085396

Experience you can trust.